



Notes

1. Conditions to be dry at time of application.
2. Remove laitance with wire brush over area to be treated and remove dust.
3. Sealing sheet to be minimum of 2mm thick with red masking tape (Sikadur-Combiflex S6-20 sheet or similar approved).
4. Proprietary epoxy resin adhesive to be compatible with sealing sheet used.
5. Apply epoxy adhesive to surface with trowel, serrated spreader or stiff nylon brush up to joint approximately 1mm thick.
6. Place sealing sheet strip centrally over joint and lap up parapet upstand 50mm bed into adhesive.
7. Apply further coat approx. 1mm thick of epoxy adhesive leaving central strip 20mm wide over joint clear of adhesive.
8. Allow to cure in accordance with manufacturer's recommendations.
9. Not to be used for joints where movements will be greater than 75% of the gap width.
10. Joint system to be compatible with waterproofing


Rev:	Date:	Description:	Approved by:
AMENDMENT DETAILS			



Checked by:	GP	Approved by:	SB
-------------	----	--------------	----

ISSUED 12/05/17

Expansion Joint for  
Movement up to 15mm

This is a typical detail and may require conversion to a full scheme specific drawing.

NOT TO SCALE  
(all units in millimetres)

**Disclaimer :** Before making use of this detail, any designer or third party must ensure that it satisfies all requirements of the scheme to which it is being applied. Lincolnshire County Council accept no responsibility for third party use of this Standard Detail.

**SD/23/1**  
Standard Detail Number

Revision Number