



Notes

1. A yellow PVC or polythene marker tape. The tape shall be printed in black with the wording 'CAUTION - STREET LIGHTING CABLE BELOW' or words to that effect approved by the Engineer.
2. Lightly compacted graded sand passing 2mm sieve.
3. Trench backfilled with the original materials from which all large stones have been removed. Original topsoil and turf shall be used where applicable.

Rev:	Date:	Description:	Approved by:
AMENDMENT DETAILS			

Rev:	Date:	Description:	Approved by:
AMENDMENT DETAILS			



Checked by:	PC	Approved by:	SB
-------------	----	--------------	----

ISSUED	04/12/14
--------	----------

Street Lighting Installation  
Cable Trench in Verge

This is a typical detail and may require conversion to a full scheme specific drawing.

NOT TO SCALE  
(all units in millimetres)

**Disclaimer :** Before making use of this detail, any designer or third party must ensure that it satisfies all requirements of the scheme to which it is being applied. Lincolnshire County Council accept no responsibility for third party use of this Standard Detail.

**SD/14/6A**  
Standard Detail Number

Revision Number

Revision