



- Notes**
1. Pre-cast concrete tactile paving on ST3 concrete 150mm thick to clause 2602.
  2. Tactile paving shall be 'Dimple' blocks 200mm x 133mm x 60mm.
  3. See also drawings SD/11/23 - 27.
  4. Minimum width at zebra crossing shall be 2.4m. (usual minimum width 3.0m)
  5. Tactile paving colour varies with crossing type. At controlled crossings use red paving. At uncontrolled crossings use buff paving. The orientation of raised texture MUST align with the direction of travel on the crossing.
  6. Controlled crossings are Pelican, Toucan, Puffin, Zebra, Pegasus and signalised junctions which incorporate illuminated and / or audible warning pedestrian control.
  7. Uncontrolled crossings are any crossing not mentioned in Note 6.
  8. All requirements to comply with principles set out in DETR 'Guidance on the use of Tactile Paving Surfaces' 1998 or subsequent revisions.
  9. Tactile paving shall be concrete 'Dimple' blocks (unless otherwise stated) 200mm x 133mm x 60mm laid on 30mm sand, 100mm AC20 dense binder and 150mm Type 1 sub-base.
  10. Area of tactile block must be surrounded by 150mm x 50mm footway edging (See SD/11/4)
  11. Minimum size of cut block shall be one third.
  12. 400mm x 400mm x 50mm Dimple slabs may be used to maintain existing areas where less than 20% require replacement.
  13. Type K3 'flush' kerbs to be bull nose finish with a nominal upstand of 6mm.

Rev:	Date:	Description:	Approved by:
AMENDMENT DETAILS			



Checked by:	Approved by:	GP
ISSUED	SB	

**Textured Footway Surfaces at Pedestrian Crossings Points**

This is a typical detail and may require conversion to a full scheme specific drawing. NOT TO SCALE (all units in millimetres)

**Disclaimer :** Before making use of this detail, any designer or third party must ensure that it satisfies all requirements of the scheme to which it is being applied. Lincolnshire County Council accept no responsibility for third party use of this Standard Detail.

<b>SD/11/6</b> Standard Detail Number	Revision Number
--	-----------------

Revision