



Notes

1. Pillars shall be fitted with Tri-locks, be galvanised and finished black.
2. The door of the pillar shall bear an electrical safety sticker with the legend 'DANGER 230 VOLTS'.
3. 6mm brass earthing points shall be fitted inside adjacent to the door and to the door itself. They shall each be supplied with 2 No. brass nuts and washers.
4. The door or the pillar shall be indelibly marked with information indicating that it supplies Traffic Signals equipment.
5. To be Anti graffiti coated following installation.

Rev:	Date:	Description:	Approved by:
AMENDMENT DETAILS			

Lincolnshire
COUNTY COUNCIL

Checked by:	GP	Approved by:	SB
ISSUED		12/05/17	

Power Supply Pillar
Traffic Signals

This is a typical detail and may require conversion to a full scheme specific drawing.

NOT TO SCALE
(all units in millimetres)

Disclaimer : Before making use of this detail, any designer or third party must ensure that it satisfies all requirements of the scheme to which it is being applied. Lincolnshire County Council accept no responsibility for third party use of this Standard Detail.

SD/12/20
Standard Detail Number

Revision Number

Revision